

---

Bachelors Theses

Student Theses and Dissertations

---

1915

## Effect of compression and transmission on the illuminating and heating value of carburetted water-gas

Horace Herbert Clark

Follow this and additional works at: [https://scholarsmine.mst.edu/bachelors\\_theses](https://scholarsmine.mst.edu/bachelors_theses)



Part of the [Mining Engineering Commons](#)

Department: Mining Engineering

---

### Recommended Citation

Clark, Horace Herbert, "Effect of compression and transmission on the illuminating and heating value of carburetted water-gas" (1915). *Bachelors Theses*. 174.

[https://scholarsmine.mst.edu/bachelors\\_theses/174](https://scholarsmine.mst.edu/bachelors_theses/174)

This Thesis - Open Access is brought to you for free and open access by Scholars' Mine. It has been accepted for inclusion in Bachelors Theses by an authorized administrator of Scholars' Mine. This work is protected by U. S. Copyright Law. Unauthorized use including reproduction for redistribution requires the permission of the copyright holder. For more information, please contact [scholarsmine@mst.edu](mailto:scholarsmine@mst.edu).

EFFECT OF COMPRESSION  
AND TRANSMISSION ON  
THE  
ILLUMINATING AND HEATING VALUE OF  
CARBURETTED WATER-GAS

BY

HORACE H CLARK

A THESIS FOR THE DEGREE OF BACHELOR OF SCIENCE IN MINE ENGINEERING  
SCHOOL OF MINES AND METALLURGY  
UNIVERSITY OF MISSOURI  
ROLLA, MO.

*Approved April 1, 1915.  
A. L. McKee  
Professor of Physics*

THE EFFECT OF COMPRESSION

upon the  
HEATING VALUE AND  
ILLUMINATING POWER OF CARBURETTED WATER GAS

by HORACE H. CLARK -----

The object of this series of tests was to determine the effect of compression upon the candle power of carburetted water gas, as made in the daily operation of a three piece water gas machine, cooled in condensers, passed through shavings, scrubbers and oxide material, and thence into a storage holder, ready for compression and distribution.

The apparatus consisted of a small Westinghouse air compressor; nine storage tanks of six inch wrought iron pipe; transfer pump; pressure regulator; standard one hundred inch bar photometer, complete, with regulators, clock, meter, pentane lamp, etc., gas analysis outfit, complete; also gages, thermometers, etc.

The compressor was fastened to the wall of the Boiler Room, adjoining the building in which the tests were made, so that the gas was not exposed to cold. No outside pipe being necessary.

The gas supply line from the holder was two hundred feet of two inch pipe, well protected from frost. The line from the compressor to the storage tanks was of two inch pipe, reduced to one inch at the header for the nine storage tanks.

This line was run indoors and protected from frost. The header for the tanks was made up as shown in Fig. I. All unions were ground joint; and all cocks were brass, of the high pressure type.

The nine storage tanks, which were of six inch threaded pipe, were designed theoretically so that the longest tank would hold enough gas for all tests. This eliminated any possibility of variation of the gas supply which might have occurred had samples for different pressures been taken from the works Holder. The dimensions of the storage tanks are given in Table I.

The pump used for transferring the gas from one tank to the next, was a simple brass hand pump, having brass check valves, both inlet and outlet being below the piston. The piston was solid with large cup leathers, and had a diameter of three inches with a three and one-half inch stroke. A water gage was placed on the inlet of the pump and by slowly opening the stop cock, the relative pressure in the tank being exhausted could be seen. At no time was a negative pressure allowed; that is, a pressure below atmospheric. On the outlet of the pump was placed a pressure gage reading to fifty pounds by half pounds, and a thermometer. Any heating of the gas was corrected so that the desired pressure at 60° F. was obtained.

A Williamson Regulator was used to reduce the pressure

in the tanks from pounds to inches water. This was placed in the line to the photometer room as shown in Fig. II. This regulator handled all pressures from five pounds to forty-five pounds without variation.

The Photometer Room and Laboratory were situated on the same floor and convenient to the storage tanks, as shown in Fig. II. These rooms, as well as the room in which the tanks were located, were properly heated, so that a minimum temperature of 60° F. could be maintained.

In starting the Westinghouse Compressor, considerable variation was noted in the flame at the photometer. From Fig. II. it will be seen that this fluctuation was caused by the compressor. A water gage on the inlet to the compressor showed holder pressure before the stroke, but a pressure of one inch below atmospheric pressure during the stroke. As there was danger of air leaks, and to avoid the fluctuations of the flame at the photometer; a storage tank or reciever, made of a piece of eight inch threaded pipe eight feet long, was placed in the gas line at the inlet to the compressor. The water gage now showed not less than two inches water pressure above atmospheric. This receiver removed the danger of air leaks but only partially overcame the fluctuations of the gas flame. This variation of the gas to the photometer room was avoided by putting in a by-pass between the compressor outlet and the receiver. In this by-pass

was placed a stop cock so that the amount of gas, returned from the compressor to the receiver, could be regulated. After the first full stroke of the compressor, no fluctuation of the gas was noted, when the by-pass was properly regulated. See Fig. II.

Much difficulty was experienced in making the storage tanks gas tight. When the nine tanks were assembled and subjected to fifty pounds per square inch air pressure, eighty per cent of the joints leaked. This was due to the fact that standard caps and couplings were used on threads cut by a local machine on which the taper was too great. The leaky fittings were removed and replaced with litharge and glycerine on the threads. The air test showed twenty per cent of the joints still leaking. These were removed and put on with red lead and shellac. Live steam was admitted into the tanks and all joints baked for three hours. After cooling, the air test showed ten per cent of the joints leaky. A number of these were stopped with standard six inch leak clamps and the smaller ones were calked. Air test and soap suds showed no leaks other than a pin hole here and there after the last remedy.

The nine storage tanks were tapped in the center of each cap on the header end, and in the lowest point of the caps at the far end. The latter taps were used for purging. It was the intention to remove drip and condensation from

these openings but as the quantity deposited was so small, all efforts in that direction were abandoned.

After starting the compressor and regulating to about forty strokes per minute, all gas pipes, tanks, etc. were purged until an analysis showed no air present. All cocks opening to the atmosphere were closed and the by-pass at the compressor regulated so that in ten minutes, five pounds gage pressure at 60° F. was noted in each of the nine storage tanks.

During this period, photometric tests were made on the gas from the inlet side of the compressor, and a sample taken for analysis. The corrected candle power thus found was taken as the value of the gas before compression.

A chart showing the relation between temperature and pressure was available so that any increase of temperature above 60° F. could be noted, and the increased pressure considered, so that the actual pressure desired would exist at 60° F.

When after ten minutes the pressure had reached five pounds, all stop cocks then open were closed, and the compressor stopped. The stops in the line to the photometer were now opened and the gas from the five pound tank (1) turned on. The gas passed through ten feet of three-quarter inch pipe to the regulator, thence through five feet of half-inch pipe to the low pressure regulator, the previous regulator being of

the high pressure type for reducing from pounds to inches. From the low pressure regulator the gas passed through a wet balance governor, test meter, and thence to the photometer burner, which was a seven foot/<sup>flat</sup> flame burner through which the gas flowed at the rate of five cubic feet per hour. No dry governor was used in the line between the meter and the burner; this might account for the slight variation in some of the readings of the Bar.

The gas was ignited at the burner and ten observations were made at intervals of thirty seconds. Previous to making these tests, the test flame was allowed to burn for ten minutes and the pentane standard regulated. The object in burning the gas ten minutes was to obtain the gas, from the tank, at the burner. The temperature of the gas at the meter, barometric pressure, rate of flow of gas, were noted. During this test a sample of the gas was taken for analysis.

The gas from tank (1) was now shut off, and the stop to the photometer closed. The plugs in the street tees to tanks (1) and (2) were removed and the connections for the transfer pump screwed in. The cocks on tanks (1) and (2) in Fig. III were opened slightly to purge the pump and fittings through the union - (26) Fig. III. The union was now closed and the cocks to tanks (1) and (2) opened wide. The transfer operation was now begun. During this operation the analysis of the gas sample taken from the previous test,



was made. The transferring was continued until the gage on the ten pound tank (2) showed ten pounds at 60° F. All stops were closed, pump and connection removed, and plugs replaced. The stops to the photometer were opened and the gas from tank (2) turned on. The line was purged for ten minutes as before, and ten, half minute readings taken of the candle power of the gas. A sample was taken for analysis as in the first test of the series.

This operation was repeated for each succeeding pressure or test in the series. For pressures above thirty pounds, tank (6) was used, the gas supply being obtained from tanks (7) - (8) - (9). The stops (10 -11) Fig. III, etc. were used for equalizing the pressure between tanks if necessary. The by-pass S. Fig II. was put in to help distribute the incoming gas more evenly.

After each series, all tanks were opened to the atmosphere through the header and cock (M), (Fig. II), whence the gas escaped into the open through the hose (V). Before beginning a next series, the entire system was purged as in the first series.

The gages and thermometers used during these tests were new and accurate.

The entire system of tanks was supported on six by six timbers. This clearance gave ample room to manipulate stop cocks, etc.

All tests were made as soon after compressing as possible. That is, as soon as the gas had cooled to 60° F. As these tests were made during January and February (1909), no difficulty was experienced in obtaining as low as 60° F. in the test room.

-- OBSERVATIONS --

Candle-Power and Analyses of the Gases

---

Holder	5 lbs. Pressure		10 lbs. Pressure	
23.9 Meter -.991	23.8	.991	23.3	.999
23.9 Temp. 69°	23.5	69°	23.5	69°
23.7 Barom. 29.85"	24.1	29.85"	23.4	29.84"
24.0 Tabular.972	24.2	.972	23.5	.971
24.0	24.0		23.1	
24.2 Corrected	23.6		23.1	
24.1 C. P. 24.87	23.8	24.70	23.4	24.02
24.0	24.0		23.5	
23.8 25 Candle	23.9		23.4	
<u>23.9</u> Standard	<u>23.8</u>		<u>23.0</u>	
23.95 25.00	23.87	24.83	23.32	24.14
<b>Analysis</b>				
CO <sub>2</sub> --- 3.9%	CO <sub>2</sub> --- 3.6		3.5	
Illts 11.6%	Illts 11.4		11.2	
O <sub>2</sub> 1.0%	O <sub>2</sub> 1.0%		1.0	
CO 30.3%	CO 30.4%		30.4	

## 15 lbs. Pressure

22.4	1.000
22.5	69°
22.3	29.83"
22.5	.971
22.4	
22.5	
22.5	23.07
22.5	
22.0	
22.4	
<u>22.40</u>	23.17

3.3  
11.1  
1.0  
30.5

## 20 lbs pressure

21.4	1.001
21.5	69.5°
21.3	29.81"
21.5	.970
21.1	
21.4	
21.5	22.00
21.5	
21.2	
21.4	
<u>21.38</u>	22.12

3.2  
11.1  
1.0  
30.5

## 25 lbs. Pressure

20.9	.994
20.8	70°
20.8	29.81"
20.5	.967
20.6	
20.5	
20.8	21.46
20.8	
20.4	
20.3	
<u>20.64</u>	21.58

3.1  
11.0  
1.0  
30.7

## 30 lbs. Pressure

20.1	.999
20.2	70°
20.3	29.80"
20.3	.967
20.5	
20.8	
20.4	21.11
20.8	
20.4	
20.3	
<u>20.41</u>	21.22

3.0  
11.0  
1.0  
30.7

## 35 lbs. Pressure

18.8	.992
19.6	70°
19.7	29.79"
19.4	.967
19.8	
19.2	
19.2	20.02
19.0	
18.7	
18.7	
<u>19.21</u>	20.11

3.0  
10.9  
1.0  
30.8

## 40 lbs. Pressure

18.5	1.000
18.2	70°
18.8	29.77"
19.0	.966
18.5	
18.4	
18.6	19.27
18.4	
19.0	
18.7	
<u>18.61</u>	19.38

2.9  
10.9  
1.0  
30.8

## Series 2

Holder	5 lbs. Pressure		10 lbs. Pressure		
24.2	.988	23.8	.979	23.7	1.000
24.0	65°	24.0	66°	24.0	67°
24.5	29.60"	23.8	29.62"	23.6	29.63"
24.3	.973	24.0	.971	24.0	.968
24.2		23.9		24.2	
24.3		23.9		24.2	
24.5	25.28	24.4	25.19	24.0	24.70
24.5		23.9		23.8	
24.1		24.0		24.0	
<u>24.0</u>		<u>24.0</u>		<u>23.6</u>	
24.26	25.00	23.97	24.91	23.91	24.43
4.2		4.0		3.9	
11.4		11.2		11.0	
.1.4		1.4		1.4	
30.4		30.5		30.6	

15 lbs. Pressure		20 lbs. Pressure		25 lbs. Pressure	
23.2	.996	21.0	.982	20.7	1.000
23.2	67.5°	20.9	68°	21.0	69°
23.0	29.62"	21.3	29.61"	21.2	29.61"
23.0	.967	21.0	.966	21.2	.963
22.9		21.5		21.3	
23.1		21.3		21.3	
23.4	23.90	21.2	22.33	21.0	22.01
22.8		21.8		20.7	
22.9		21.2		20.9	
<u>22.9</u>		<u>21.7</u>		<u>20.7</u>	
23.04	23.64	21.29	22.09	21.00	21.77
3.7		3.5		3.3	
10.9		10.7		10.6	
1.4		1.4		1.4	
30.6		30.7		30.8	

## 30 lbs. Pressure

20.1	.984
20.0	69°
20.4	29.61"
20.5	.963
20.5	
20.2	
20.1	21.28
20.1	
19.9	
20.0	
<u>20.18</u>	21.05

3.2  
10.4  
1.4  
30.9

## 35 lbs. Pressure

18.8	.989
19.2	69°
19.2	29.61"
19.0	.963
18.5	
19.2	
19.0	20.00
19.2	
19.0	
19.2	
<u>19.03</u>	19.78

3.1  
10.2  
1.4  
31.0

## 40 lbs. Pressure

18.7	.988
18.3	70°
18.2	29.62"
18.0	.960
18.3	
18.0	
18.6	19.37
18.3	
18.3	
<u>18.9</u>	
<u>18.36</u>	19.16

3.0  
10.1  
1.4  
31.0

## 45 lbs. Pressure

18.5	.992
18.1	70°
18.5	29.61"
18.0	.960
18.0	
18.6	
18.1	19.22
18.3	
18.6	
<u>18.3</u>	
18.30	19.00

3.0  
10.1  
1.4  
30.9

## Series 3

Holder		5 lbs. Pressure		10 lbs. Pressure	
26.0	1.000	25.5	.988	25.0	1.000
25.6	29.69"	25.0	68.5°	25.0	70°
25.8	62°	25.2	29.69"	24.8	29.69"
26.0	.984	25.0	.968	24.7	.964
25.7		25.2		24.9	
25.9		25.5		24.8	
25.6	26.21	25.3	26.11	24.8	25.75
25.6		25.3		24.7	
26.0		25.3		24.7	
<u>25.6</u>		<u>25.5</u>		<u>24.7</u>	
25.78	25.00	25.28	24.91	24.82	24.56
4.0		3.9		3.8	
12.3		12.2		12.0	
1.0		1.0		1.0	
31.2		31.2		31.3	

15 lbs. Pressure		20 lbs. pressure		25 lbs. Pressure	
23.8	.990	22.5	.995	22.0	.996
24.3	74°	22.7	75°	22.0	75°
24.3	29.68"	22.5	29.67"	22.1	29.67"
23.5	.952	23.1	.946	22.1	.946
24.2		22.3		22.2	
24.2		22.7		22.2	
23.5	25.38	23.0	24.13	22.3	23.44
24.3		22.6		22.0	
24.2		23.0		22.0	
<u>24.0</u>		<u>23.0</u>		<u>22.0</u>	
24.03	24.21	22.74	23.02	22.09	22.35
3.7		3.5		3.4	
11.8		11.7		11.5	
1.0		1.0		1.0	
31.3		31.3		31.2	

30 lbs. Pressure

21.3	.992
21.8	74°
21.8	29.67"
21.8	.953
21.8	
21.8	
21.7	22.86
21.6	
21.3	
21.3	
<u>21.62</u>	21.81

3.2  
11.4  
1.0  
31.1

35 lbs. Pressure

21.0	1.000
20.8	72°
20.9	29.68"
21.4	.958
21.1	
21.0	
21.2	22.00
21.4	
21.0	
21.0	
<u>21.08</u>	20.98

3.1  
11.3  
1.0  
31.1

40 lbs. Pressure

21.1	.991
20.8	71.5°
20.6	29.68"
20.5	.960
20.3	
20.0	
20.6	21.60
20.7	
20.6	
20.2	
<u>20.54</u>	20.60

3.0  
11.2  
1.0  
31.1

45 lbs. Pressure

21.4	1.014
21.0	70°
21.0	29.69"
21.2	.964
21.2	
20.8	
20.9	21.58
21.1	
21.00	
21.0	
<u>21.06</u>	20.58

3.0  
11.2  
1.0  
31.0



Series 4

Holder		5 Lbs. Pressure		10 Lbs. Pressure	
25.3	.992	23.9	1.000	24.2	1.004
24.7	29.60"	23.9	75°	24.1	76°
25.0	69°	24.3	29.41"	24.1	29.41"
24.9	.963	24.3	.940	24.0	.938
24.9		24.3		24.5	
24.9		24.5		24.1	
24.6	26.00	24.5	25.81	24.1	25.59
24.7		24.5		23.6	
24.7		24.2		24.2	
24.5		24.2		24.2	
<u>24.82</u>	25.00	<u>24.26</u>	24.82	<u>24.11</u>	24.61

3.8  
12.0  
0.4  
30.4

3.8  
12.0  
0.4  
30.3

3.8  
11.3  
0.4  
30.5

15 Lbs. Pressure		20 lbs. Pressure		25 lbs. Pressure	
23.4	1.000	22.3	1.000	22.1	.996
23.5	76°	22.4	75°	21.6	75.5°
23.3	29.41"	21.5	29.38"	22.1	29.38"
23.3	.938	22.3	.940	21.9	.939
23.3		22.4		22.0	
23.1		22.0		21.2	
23.0	24.84	22.3	23.54	21.6	23.22
23.5		22.0		22.0	
23.5		22.0		21.3	
<u>23.1</u>		<u>22.0</u>		<u>21.4</u>	
23.30	23.89	22.12	22.64	21.72	22.33

3.7  
11.2  
0.4  
30.6

3.7  
11.1  
0.4  
30.7

3.5  
11.1  
0.4  
30.4

30 lb. Pressure

20.8	.994
20.7	77°
21.2	29.36"
21.2	.933
21.1	
21.0	
20.8	
20.9	22.58
21.0	
<u>20.9</u>	
20.96	21.72

- 3.2
- 11.0
- 0.5
- 30.9

## Series 5

Holder		5 Lbs. Pressure		10 lbs. Pressure	
24.0	1.000	24.8	1.000	23.6	.990
24.7	69.5°	24.0	69.5°	23.8	69°
24.7	29.44"	24.4	29.44"	23.5	29.44"
24.5	.955	24.0	.955	23.2	.958
24.6		24.3		23.0	
24.3		24.6		23.4	
24.3	25.61	24.5	25.49	23.0	24.58
24.5		24.3		23.0	
24.5		24.0		23.5	
24.5		24.6		23.1	
<u>24.46</u>	25.00	<u>24.35</u>	24.90	<u>23.31</u>	24.01

3.4  
12.0  
0.9  
30.6

3.4  
12.0  
0.9  
30.6

3.3  
12.0  
0.9  
30.6

15 lbs. Pressure		20 lbs. pressure		25 lbs. pressure	
22.1	.994	21.7	.994	21.8	1.000
22.6	69°	21.4	29.44"	21.1	69°
22.9	29.44"	21.4	69°	21.1	29.44"
22.5	.958	21.6	.958	21.2	.958
22.4		21.7		21.2	
22.4		21.6		21.4	
22.1		21.4	22.64	21.4	22.25
22.8	23.62	21.4		21.5	
22.6		22.0		21.8	
22.5		21.4		21.6	
<u>22.49</u>	23.08	<u>21.56</u>	22.12	<u>21.41</u>	21.74

3.1  
12.0  
0.9  
30.6

2.9  
11.8  
0.9  
30.7

2.9  
11.8  
0.9  
30.7

## 30 lbs. Pressure

20.4	.980
20.9	69.5°
21.0	29.45"
21.0	.955
20.0	
20;3	
21.0	22.09
20.7	
20.6	
<u>20.8</u>	
20.67	21.59

2.9  
11.8  
0.9  
30.8

Series 6

Holder		5 lbs. pressure		10 lbs. pressure	
24.0	1.000	23.5	.996	23.4	1.000
24.0	69°	23.6	69°	22.7	72°
23.9	29.60"	23.6	29.60	22.7	29.56"
23.8	.963	23.7	.963	22.7	.953
23.8		23.4		22.8	
23.8		23.8		23.0	
23.8		23.7	24.63	23.0	24.00
23.9	24.86	23.6		23.0	
24.0		23.4		22.8	
24.4		23.9		22.6	
<u>23.94</u>	25.00	<u>23.62</u>	24.78	<u>22.87</u>	24.14
	3.1		3.1		3.0
	12.0		12.0		11.6
	0.9		0.9		1.0
	30.9		30.9		30.9

15 lbs. pressure		20 lbs. pressure	
21.4	1.000	21.2	1.000
22.0	72°	21.0	71°
22.1	29.56"	21.1	29.49"
22.2	.953	21.2	.954
22.2		21.0	
22.2		21.0	
22.3	23.05	21.0	
22.0		21.1	22.10
21.8		21.1	
<u>21.5</u>		<u>21.1</u>	
21.97	23.18	21.08	22.23
	3.0		3.0
	11.6		11.6
	1.1		1.1
	30.8		30.9

## Series 7

Holder		5 lbs. pressure		10 lbs. pressure	
21.4	1.000	21.2	.993	21.5	.997
21.6	72°	21.4	72.5°	21.4	72.5°
21.2	29.36"	21.0	29.34"	21.3	29.34"
21.0	.947	21.2	.945	21.4	.945
22.0		21.2		20.7	
22.0		21.1		20.7	
21.9	22.65	21.0	22.58	21.0	22.30
21.0		21.4		20.9	
21.0		21.3		20.4	
<u>21.4</u>		<u>21.2</u>		<u>20.8</u>	
21.45	25.00	21.20	24.92	21.01	24.62

2.3  
11.7  
0.7  
29.8

2.3  
11.7  
0.7  
29.8

2.3  
11.7  
0.7  
29.9

## 15# pressure

20.6	.995
20.0	72.5°
20.5	29.34"
20.3	.945
20.4	
20.2	
20.6	21.73
20.6	
20.7	
<u>20.4</u>	
20.43	23.99

2.3  
11.7  
0.7  
29.8

## 20# pressure

20.0	1.000
20.6	72.5°
19.9	29.34"
20.6	.945
20.7	
20.2	
20.3	21.51
20.5	
20.5	
<u>20.0</u>	
20.33	23.75

2.3  
11.6  
0.7  
29.8

## 25# pressure

19.7	.994
19.8	72°
19.4	29.35"
19.4	.946
19.0	
19.5	
19.8	20.82
19.6	
19.8	
<u>19.5</u>	
19.55	22.99

2.2  
11.5  
0.7  
30.0

## 30# pressure

19.5	.994
19.3	72°
19.2	29.36"
19.4	.947
19.1	
19.7	
19.1	20.50
19.2	
18.9	
19.2	
<u>19.26</u>	22.63

2.1  
11.5  
0.7  
31.0

## 35# pressure

18.5	.986
18.2	72°
19.2	29.36"
18.5	.947
18.4	
18.5	
18.5	19.89
18.5	
19.0	
18.5	
<u>18.58</u>	21.96

2.0  
11.4  
0.7  
31.1

## 40# pressure

19.0	1.000
18.9	71°
18.7	29.37"
18.8	.950
18.5	
19.2	
18.8	19.80
18.7	
18.8	
18.7	
<u>18.81</u>	21.86

2.0  
11.4  
0.7  
31.1

## 45# pressure

18.5	.996
18.4	72°
18.6	29.36"
18.7	.947
18.5	
18.4	
18.4	19.73
18.4	
18.6	
18.7	
<u>18.52</u>	21.78

2.0  
11.4  
0.7  
31.0

## Series 8

Holder

5# pressure

10# pressure

19.6	1.000
19.4	28.74"
19.3	67.5°
19.4	.937
19.4	
19.5	
19.3	20.71
19.2	
19.2	
19.7	
<u>19.40</u>	25.00

19.3	1.000
19.3	67.5°
19.6	28.74"
18.7	.937
18.7	
19.0	
19.3	20.46
19.3	
19.3	
19.2	
<u>19.17</u>	24.70

18.6	1.000
18.2	67.5°
18.0	28.65"
18.3	.933
18.0	
18.5	
18.2	19.56
18.7	
18.0	
<u>18.0</u>	
18.25	23.62

4.9  
10.3  
1.4  
30.7

4.9  
10.3  
1.4  
30.7

4.8  
10.2  
1.4  
30.8

15# pressure

20# pressure

25# pressure

17.8	1.000
17.5	67.5°
17.6	28.65"
17.0	.933
17.3	
17.0	
16.8	18.47
17.0	
17.0	
17.3	
<u>17.23</u>	22.30

16.8	.998
16.4	67.5°
16.0	28.68"
15.8	.934
15.2	
16.4	
15.9	17.25
16.1	
16.2	
16.0	
<u>16.08</u>	20.83

16.1	.990
15.5	67.5°
15.5	28.64"
15.2	.933
15.3	
16.1	
15.6	17.04
15.7	
16.2	
16.2	
<u>15.74</u>	20.57

4.6  
10.1  
1.4  
30.9

4.4  
10.0  
1.4  
30.9

4.3  
10.0  
1.4  
31.0



## 30# pressure

16.6	1.000
15.8	67.5°
15.3	28.64"
15.8	.933
15.5	
15.4	
16.2	16.87
15.1	
16.0	
<u>15.7</u>	
15.74	20.37

4.2  
10.0  
1.4  
31.1

## 35# pressure

15.2	1.000
15.3	67.5°
15.5	28.64"
15.6	.933
15.4	
15.0	
15.8	16.55
16.0	
15.6	
<u>15.0</u>	
15.44	20.00

4.1  
9.9  
1.4  
31.1

## 40# pressure

15.0	1.000
15.6	67.5°
15.2	28.64"
15.0	.933
15.0	
15.6	
15.3	16.36
15.3	
15.0	
<u>15.6</u>	
15.26	19.85

4.0  
9.9  
1.4  
31.1

## 45# pressure

15.8	1.000
15.5	67.5°
14.5	28.64"
14.6	.933
15.0	
15.0	
15.4	16.08
14.4	
14.5	
<u>15.3</u>	
15.00	19.42

4.0  
9.9  
1.4  
31.1

Series 9

Holder		5# pressure		10# pressure	
22.3	1.000	21.8	.987	20.6	.990
22.2	72.5°	21.6	73.5°	20.5	73°
22.0	29.23"	21.3	29.19"	20.3	29.20"
22.2	.940	21.2	.938	20.4	.940
22.0		21.2		20.4	
22.3		21.2		20.3	
21.9	23.50	21.5	23.15	20.1	21.90
21.8		21.4		20.6	
22.2		21.6		20.5	
<u>22.0</u>		<u>21.6</u>		<u>20.1</u>	
22.09	25.00	21.44	24.63	20.38	23.30

4.7	4.6	4.6
11.2	11.2	11.0
1.0	1.0	1.0
30.2	30.3	30.3

15# pressure		20# pressure		25# pressure	
19.4	.990	19.0	.990	18.3	.990
19.4	73°	18.8	73°	19.0	73°
19.2	29.22"	18.7	29.22"	18.4	29.22"
19.3	.940	19.0	.940	18.3	.940
19.4		19.0		19.1	
19.6		18.9		18.2	
19.0	20.74	19.2	20.32	18.6	20.05
19.5		18.7		18.7	
19.0		18.6		19.3	
<u>19.2</u>		<u>19.1</u>		<u>18.7</u>	
19.30	22.06	18.90	21.62	18.66	21.33

4.3	4.3	4.2
10.9	10.9	10.9
1.0	1.1	1.1
30.5	30.6	30.7

## 30# pressure

18.3	1.005
17.8	72.5°
18.3	29.23"
18.0	.940
17.7	
18.1	
18.1	19.07
18.0	
17.8	
18.0	
<u>18.01</u>	20.29

4.2  
10.7  
1.1  
30.7

## 35# pressure

17.0	.996
17.3	72.5°
17.3	29.24"
17.2	.941
16.9	
17.4	
17.0	18.33
17.0	
17.5	
17.1	
<u>17.17</u>	19.50

4.0  
10.6  
1.1  
30.7

## 40# pressure

17.2	1.000
17.1	72.5°
17.0	29.24"
17.1	.941
17.4	
17.3	
17.0	18.22
16.8	
17.5	
17.0	
<u>17.14</u>	19.38

4.0  
10.6  
1.2  
30.7

## 45# pressure

17.5	1.006
17.0	72.5°
17.4	29.24"
16.9	.941
17.0	
16.9	
16.9	18.05
16.9	
17.0	
17.0	
<u>17.05</u>	19.20

4.0  
10.6  
1.2  
30.5

## Series 10

Holder		5# pressure		10# pressure	
19.9	1.000	20.0	1.000	19.3	.991
20.0	68.5°	19.9	68.5°	19.0	68°
19.8	28.59"	19.9	28.59"	18.0	28.58"
19.9	.930	19.3	.930	18.7	.930
20.0		19.6		19.0	
20.0		19.5		18.7	
20.0	21.40	19.2	21.11	18.5	20.35
19.9		19.7		18.5	
19.7		20.0		19.3	
<u>19.8</u>		<u>19.2</u>		<u>18.5</u>	
19.90	25.00	19.63	24.67	18.75	23.78

5.3  
10.3  
2.0  
30.0

5.1  
10.2  
2.0  
30.0

5.1  
10.1  
2.0  
30.1

## 15# pressure

18.0	.997
18.6	68°
18.0	28.56"
17.7	.930
18.0	
17.6	
17.6	19.35
17.7	
18.0	
<u>18.0</u>	
17.92	22.43

5.1  
10.0  
2.0  
30.1

## 20# pressure

17.0	.992
16.4	68°
16.6	28.56"
16.4	.930
15.0	
16.7	
16.6	17.78
16.0	
16.0	
<u>16.3</u>	
16.40	20.78

4.6  
10.0  
2.0  
30.2

## 25# pressure

15.8	.988
15.9	67.5°
15.9	28.56"
15.8	.932
15.8	
16.0	
16.0	17.18
15.5	
15.7	
<u>15.8</u>	
15.82	20.08

4.5  
9.9  
2.0  
30.2

30# pressure

15.8	.985
15.0	67°
15.6	28.56"
15.6	.933
14.9	
15.6	
15.6	16.84
15.4	
15.4	
15.8	
<u>15.47</u>	19.68

4.5  
9.9  
2.0  
30.2

35# pressure

15.4	.990
15.1	67°
15.2	28.56"
15.0	.933
15.6	
15.1	
15.0	16.51
15.2	
15.2	
15.6	
<u>15.24</u>	19.28

4.4  
9.9  
2.0  
30.3

40# pressure

15.3	.985
15.0	67°
14.9	28.56"
14.9	.933
15.1	
15.0	
15.0	16.42
15.0	
15.3	
15.4	
<u>15.09</u>	19.18

4.0  
9.8  
2.0  
30.4

45# pressure

15.0	.990
14.9	67°
14.8	28.56"
15.0	.933
15.2	
15.1	
14.7	16.25
15.0	
15.2	
15.1	
<u>15.00</u>	19.100

4.0  
9.8  
2.0  
30.5

## Series 11

Holder		5# pressure		10# pressure	
24.5	1.000	24.4	.994	24.0	.995
24.8	77°	24.5	77°	23.8	79°
24.6	29.33	24.0	29.33"	23.9	29.30"
24.6	.933	24.4	.933	23.6	.926
24.5		24.1		23.8	
24.2		24.2		23.5	
24.2	26.24	24.1	26.14	23.8	25.79
24.2		24.3		23.7	
24.6		24.2		23.9	
24.6		24.1		23.5	
<u>24.6</u>		<u>24.1</u>		<u>23.5</u>	
24.48	25.00	24.23	24.91	23.75	24.58

3.4  
12.5  
0.6  
30.0

3.4  
12.4  
0.6  
30.0

3.4  
12.4  
0.6  
30.6

## 15# pressure

23.7	.995
23.3	79°
23.4	29.30"
23.6	.926
23.5	
23.3	
23.3	25.45
23.7	
23.6	
23.1	
<u>23.45</u>	24.25

3.2  
12.2  
0.6  
31.6

## 20# pressure

22.5	1.000
22.2	79°
22.4	29.30"
22.5	.926
22.7	
22.7	
22.6	24.38
22.7	
22.7	
22.7	
<u>22.7</u>	
22.57	23.23

2.6  
12.0  
0.7  
31.4

## 25# pressure

21.8	1.000
21.6	81°
21.5	29.33"
21.7	.922
21.6	
21.8	
21.8	23.45
21.4	
21.4	
21.6	
<u>21.6</u>	
21.62	22.34

2.6  
11.8  
0.7  
30.5

## 30# pressure

21.0	1.000
21.3	81 <sup>0</sup>
21.2	29.33"
21.1	.922
21.5	
21.5	
21.6	23.09
21.3	
21.1	
<u>21.3</u>	
21.29	22.00

2.6  
11.6  
0.7  
30.8

Series 12

Holder

5# pressure

10# pressure

25.0	1.003
24.8	67°
25.0	29.90"
24.7	.979
25.0	
25.0	
24.9	25.37
24.7	
24.5	
24.9	
<u>24.85</u>	25.00

24.6	1.000
24.9	67°
24.5	29.90
25.0	.979
25.0	
24.9	
24.9	25.28
24.7	
24.6	
24.5	
<u>24.76</u>	24.92

24.0	1.000
24.3	65°
24.5	29.95"
24.5	.986
24.4	
24.5	
24.4	24.78
24.5	
24.5	
24.4	
<u>24.40</u>	24.42

2.5  
11.4  
1.0  
30.2

2.5  
11.4  
1.0  
30.3

2.5  
11.3  
1.0  
30.3

15# pressure

20# pressure

25# pressure

23.4	.996
23.2	67°
23.3	29.90"
23.2	.979
23.4	
23.3	
23.5	24.00
23.5	
23.4	
23.7	
<u>23.39</u>	23.65

22.5	.984
22.6	67°
22.4	29.92"
23.1	.980
22.4	
22.5	
22.8	23.50
23.1	
22.6	
22.6	
<u>22.66</u>	23.16

22.9	.986
22.9	67°
22.4	29.93"
22.5	.980
22.4	
22.4	
22.4	23.36
22.4	
22.5	
22.9	
<u>22.57</u>	23.02

2.5  
11.2  
1.0  
30.4

2.4  
11.2  
1.0  
30.4

2.4  
11.2  
1.0  
30.5



## 30# pressure

22.7	1.000
22.3	65°
22.5	29.95"
22.7	.986
22.4	
22.5	
22.8	22.90
22.8	
22.8	
<u>22.3</u>	
22.58	22.57

2.3  
11.1  
1.0  
30.5

## Series 13

Holder	5# pressure		30# pressure		
25.8	1.000	25.7	1.000	22.9	1.000
25.1	58°	25.0	58°	22.8	59°
25.6	29.90"	26.1	29.90"	22.5	29.90"
25.1	1.002	25.5	1.002	22.5	.999
26.2		25.0		22.8	
26.2		25.0		22.5	
26.8	25.58	25.4	25.47	22.6	22.60
25.5		26.1		22.3	
25.2		25.7		22.6	
<u>25.3</u>		<u>25.2</u>		<u>22.4</u>	
25.58	25.00	25.47	24.90	22.59	22.09
	3.0		3.0		2.5
	12.1		12.0		11.8
	0.8		0.8		0.8
	30.1		30.1		30.3

### Conclusions

The results obtained show that there is a loss of from 9.49 to 21.31 per cent of the candle power of the gas when compressed to 30 lbs. per sq. in. gage pressure. When compressed to 45 lb. per sq. in. the loss is from 12.88 to 24.07 per cent. Referring to Charts 1 and 2, we note that the greatest loss occurs between 5 and 20 lbs. pressure. Above 20 lbs. the loss decreases, until between 40 and 45 lbs. the drop in candle power per pound increased pressure is very small. Evidently compression may be carried to 45 or 50 lbs. without greatly increasing the drop in candle power over that noted at 30 lbs.

Referring to Table II, Series 7, we note a loss of 9.49% of the initial candle power when the gas is compressed to 30 lbs. When compressed to 45 lbs. the additional loss is only 3.39 per cent. The heats were good when this gas was made, the per cent CO<sub>2</sub> is low, and the gas stands compression well. By "Good heats" is meant, proper heat in the generator to decompose the steam; heat enough in the carburettor to properly vaporize the oil; and a high and carefully regulated temperature in the superheater in order to thoroughly fix the gases.

Next consider Series 10, Table II. Here we have a gas made while the heats were poor. This gas contains considerable CO<sub>2</sub> and lost 21.31 per cent of its candle power when

compressed to 30 lbs. When compressed to 45 lbs. the additional loss is 2.76 per cent. This gas is hardly suitable for compression for distribution at 30 lbs. although if distributed at 55 or 60 lbs. the total loss at 60 lbs would be only slightly greater than the loss at 60 lbs. of the gas in Series 7, Series 7 and Series 10 represent the extremes of observations. All other tests came within these limits.

Evidently, gas may be compressed to 45 lbs. for transmission without much additional loss above that lost in compressing to 30 lbs. There is an additional loss in candle power due to transmission which is not considered in this report. When gas is transmitted, two factors, low temperature and age, must be considered; as well as the factor of compression. In this series of tests the minimum temperature was 60° F. and candle power tests were taken immediately after compressing the gas.

The effect of transmission upon the candle power of the gas, may be great or little, depending upon conditions. Many precautions must be taken while making observations on high pressure distributing systems; that is, in systems where the gas is reduced to water pressure at the consumers house. A gas which tested 25 candles uncompressed at the works might give only half that amount at a point ten or twelve miles from the works under unfavorable conditions.

An unfavorable condition would be one in which there was frost in the ground and the test flame, a flat flame burner, was supplied from the dead end of a long lateral say 2000 ft. of 2 in. pipe, supplying only a few consumers. Here the factors, low temperature and age, must be considered.

With a gas of the average quality and showing 25 candle power before compression, we may expect a loss of about 3.50 candles, when the gas is compressed to 30 lbs. If the only varying factor is the quantity of gas oil used, then the loss at any other initial candle power is proportional. Upon this theory is based Chart II.

Compression decreases the percentage of  $\text{CO}_2$  in the gas. This  $\text{CO}_2$  probably dissolves in the vapor condensed. The decrease is small, however, ranging from 0.2 to 1.0 per cent as noted in the analysis, or from 8.7 to 23.8 per cent of the  $\text{CO}_2$  present in the uncompressed gas, pressure 30 lbs.

The decrease in illuminants is not at all in proportion to the drop in candle power. No relation apparently exists. The greatest drop in candle power noted was 5.45 at 45 lbs. with a loss of only 0.6 per cent in illuminants. A gas which lost only 2.92 candles when compressed to 45 lbs. dropped 0.3 per cent of illuminants according to the analysis. Compressed gas constituents seem to be less active, chemically, than the same constituents in uncompressed gas. If we compare the illuminants with "dust or heavy vapor and say

that they settle out more quickly in the more dense, compressed gas, causing the gas to "age" quickly, we might explain one point, but the high percentage of illuminants in the compressed gas is still unexplained.

The fact that the illuminants present in compressed gas do not burn with the same intensity as when present in uncompressed gas, should condemn candle power observations upon carburetted water gas. Calorific tests would be more reliable as a method of comparison.

All analyses contained in this report were made in a Morehead Gas Burette, under exactly the same conditions for all tests, so that the results obtained would be comparable.

The results obtained show almost conclusively that the loss in candle power due to compression can be reduced to a minimum by proper manipulation of the blast and steam in the gas machine. That is assuming the coke in the generator is low in sulphur and ash and high in fixed carbon; and that the checker brick in carburetter and superheater are clean. All operations which tend to increase the percentage of non-combustible gases in the finished gas should be avoided. When the percentage of  $\text{CO}_2$ , O and N is high, the loss due to compression is greatest, especially if the percentage of  $\text{CO}_2$  is high. See Chart #3.

To obtain the maximum candle power efficiency from a high pressure system in which the gas pressure is reduced to inches water at the consumers house, the following points, if observed, would lead to high efficiency if not the maximum. They are: Good fuel in generator, proper manipulation of blast and steam in the gas machine so as to give lowest possible percentage of non-combustible gases, especially of  $\text{CO}_2$ ; purification at about  $85^\circ\text{F}$ . with a smallest possible amount of added oxygen; storage holder water at a temperature which will not give off vapor in cold weather; transmission in pipes well protected from frost; gas consumed in Bunsen burner or equivalent such as incandescent burner, etc. Rapid movement of the gas in the mains might overcome the so-called ageing effect due to gas remaining in pipes for a considerable length of time.

Chart 4 shows the comparison of Candle Power and heating value of the gas. These curves are the average of over two thousand observations. A few results were found to vary as much as 20% from the curve, but the average is well represented (The original investigations for this subject were made by the undersigned during January and February 1909. The comparison of Illuminating Power and Heating Value was made in January 1915 and covers observations for a period of several years.)

RESPECTFULLY SUBMITTED

---

MARCH 25th, 1915







FIG. I.

- Nº 1 - STORAGE TANK (6" PIPE)
- 2 - CAP (6")
- 3 - CORPORATION COCK (1/2")
- 4 - GROUND JOINT UNION (1/2")
- 5 - NIPPLE (1/2" - 3" LONG)
- 6 - HIGH PRESSURE COCK (1")
- 7 - " " " "
- 8 - NIPPLE (1" - 4" LONG)
- 9 - " " " "
- 10 - PLAIN TEE (1" X 1" X 1/2")
- 11 - STREET TEE (1/2")
- 12 - PLUG (1/2").



TOP VIEW

FIG. III



SHOWING POSITION OF GAGE AND THERMOMETER ON PRESSURE SIDE

- 1. TANK #1.
- 2. TANK #2.
- 3. CAPS (6")
- 4-5. CORPORATION COCKS
- 6-7. GROUND JOINT UNIONS.
- 8-9. NIPPLES.
- 10-11-12. HIGH PRESSURE COCKS
- 13-14-15-16. NIPPLES
- 17-18. -NIPPLES.
- 19-20. -PLAIN ELLS.
- 21-22. -PLAIN TEES.
- 23-24. NIPPLES
- 25-26. GROUND JOINT UNIONS.
- 27-28. NIPPLES
- 29. TRANSFER PUMP
- 30. THERMOMETER
- 31. GAGE
- 32. PLAIN TEE
- 33. STREET TEE
- 34. " "
- 35. NIPPLE
- 36. WATER GAGE







FIG. 11

VERTICAL PLAN

- A - HOLDER OUTLET LINE.
- B - LINE TO COMPRESSOR - 2" PIPE, 200' LONG
- C - LINE TO PHOTOMETER - 3/4" PIPE, 220' LONG
- D - STREET TEE FROM WHICH A AND B COME OFF.
- E - RECEIVER 8" DIAM 8' LONG
- F - SMALL WESTINGHOUSE COMPRESSOR.
- G - BY-PASS - 3/4" PIPE
- H - STOP FOR ATTACHING WATER GAGE
- I - LOW PRESSURE REGULATOR
- J - WILLIAMSON HIGH PRESSURE REGULATOR.
- K - HEADER FOR TANKS
- L - TANKS, END VIEW
- M - OPENING TO OUT-DOOR BLOW-OFF
- N - LINE TO PHOTOMETER ROOM - 3/4" PIPE
- O - LINE FROM COMPRESSOR TO TANKS
- P - PHOTOMETER FLAME
- R - REGULATOR VENT
- S - PRESSURE EQUALIZER FOR HEADER
- T - THERMOMETER
- U - PRESSURE GAGE
- X - STOP COCKS

HORIZONTAL PLAN



41

TABLE II

SERIES NO	CANDLE POWER BEFORE COMPRESSION	CANDLE POWER AFTER COMPRESSING TO 30 LBS. GAGE	LOSS IN CANDLE POWER DUE TO COMPRESSION	PERCENTAGE LOSS AT 30# OF CANDLE POWER	PERCENT CO <sub>2</sub> BEFORE COMPRESSION	HEATS IN GAS MACHINE	CANDLE POWER WHEN COMPRESSED TO 45 LBS GAGE	LOSS IN CANDLE POWER	PERCENTAGE LOSS AT 45LBS GAGE
1	24.87	21.11	3.76	15.12	3.9	POOR			
2	25.28	21.28	4.00	15.82	4.2	POOR	19.22	6.06	23.98
3	26.21	22.86	3.35	12.78	4.0	GOOD	21.58	4.63	17.66
4	26.00	22.58	3.42	13.15	3.8	FAIR			
5	25.61	22.09	3.52	13.75	3.4	POOR			
6	24.86				3.1	GOOD			
7	22.65	20.50	2.15	9.49	2.3	GOOD	19.73	2.92	12.88
8	20.71	16.87	3.84	18.54	4.9	POOR	16.08	4.63	22.35
9	23.50	19.07	4.43	18.85	4.7	POOR	18.05	5.45	23.19
10	21.40	16.84	4.56	21.31	5.3	POOR	16.25	5.15	24.07
11	26.24	23.09	3.15	12.00	3.4	FAIR			
12	25.37	22.90	2.47	13.67	2.5	GOOD			
13	25.58	22.60	2.98	11.65	3.0	GOOD			
A	B	C	D	E	F	G	H	I	J
	AVERAGE	"	"	"	"	"	"	"	"
	24.45	20.98	3.47	14.19	3.78	GENERAL	18.48	4.81	20.65




Chart 1  
Actual Candle Power  
Observations

Candle Power of the Gas Corrected to 60° F and 30" Barometer  
corrected

Gage Pressure Pounds per Sq. In at 60° F





Chart 2


Gage Pressure at 60°F Pounds per Sq In.

Candle Power Corrected to 60°F and Reduced to 25 Candles for Comparison.

Chart #3



47  
X  
GROSS



CURVE SHOWING RELATION BETWEEN CANDLE POWER AND HEAT VALUE OF CARBURETTED WATER GAS

Chart 4

CANDLE POWER AT 5 1/2 HR RATE BY BRAY'S SPECIAL 7 BURNER.

TABLE-I-

40

TEST NO	TANK NO	VOLUME OF GAS AT 57.5 IN. WATER PRES. REQUIRED FOR THE TESTS. CU. FT.	LOSS ASSUMED DUE TO LEAKAGE ETC. CU. FT.	ALLOWED FOR TEST CU. FT.	GAGE PRESSURE POUNDS PER SQ. IN.	LENGTH OF TANK INSIDE DIMENSION CAP TO CAP FEET.	VOLUME OF GAS AT GAGE PRESSURE CONTAINED IN TANK. CU. FT.	VOL. OF GAS AT 0.2# CONTAINED IN TANK CU. FT.	VOL. USED AT 0.2# FOR TEST. CU. FT.	VOL. AT 0.2# LEFT IN TANK CU. FT.	VOL. AT 0.2# REQUIRED FOR COMPRESSION CU. FT.	SURPLUS GAS AT 0.2# REMAINING IN TANK	TEMPERATURE DEGS. F.
1			0.00	1.25	0.2								
2	1	11.85	0.00	1.25	5.0	58.000	11.600	15.55	1.25	14.30	15.55	2.33	60
3	2	10.60	0.02	1.25	10.0	35.647	7.1293	14.30	1.27	13.03	11.97	3.09	60
4	3	9.33	0.04	1.25	15.0	24.597	4.9193	13.03	1.29	11.74	9.94	3.86	60
5	4	8.04	0.06	1.25	20.0	16.690	3.3380	11.74	1.31	10.43	7.88	4.63	60
6	5	6.73	0.08	1.25	25.0	10.739	2.1477	10.43	1.33	9.10	5.80	5.41	60
7	6	5.40	0.10	1.25	30.0	6.083	1.2166	9.10	1.35	7.75	3.69	3.63	60
8	6	4.05	0.10	1.25	35.0	6.083	1.2166	7.75	1.35	6.40	4.12	1.88	60
9	6	2.70	0.10	1.25	40.0	6.083	1.2166	6.40	1.35	5.05	4.52	0.10	60
10	6	1.35	0.10	1.25	45.0	6.083	1.2166	5.05	1.35	3.70	4.95	3.70	60
-	7				5.0	20.000	4.0000					5.36	60
-	8				5.0	17.000	3.4000					4.56	60
-	9				5.0	16.000	3.2000					4.29	60
A	B	C	D	E	F	G	H	I	J	K	L	M	N


REMARKS:- BAROMETRIC PRESSURE 14.5 LBS PER. SQ. IN.  
 WITH A 5FT. BURNER, THE GAS USED IN THE TIME OF A TEST (15 MINUTES) WOULD BE 1.25 CU. FT. APPROXIMATELY COLUMN (C) SHOWS THE VOLUME OF GAS NECESSARY FOR THE TEST BEING MADE, AND FOR ALL SUBSEQUENT TESTS IN A SERIES  
 COLUMN (F) SHOWS THE GAGE PRESSURE AT 60° F. TO WHICH THE GAS IN THE CORRESPONDING TANK WAS COMPRESSED.  
 COL (H) IS THE CAPACITY OF THE PIPE, USING 0.2 CU FT PER LINEAR FOOT AS THE CAPACITY OF 6" WROUGHT IRON PIPE  
 COL (I) SHOWS THE CAPACITY OF THE TANK IN CU. FT. AT 0.2 LBS. GAGE. THESE FIGURES WERE FOUND BY THE FORMULA,  $V:V_1::P_1:P$ , WHERE V AND V<sub>1</sub> ARE VOLUME AND P, P THE ABSOLUTE PRESSURES.  
 IN COL (J), THE FIGURES ARE DERIVED BY ADDING THE GAS CONSUMED AND THE LEAKAGE FOR THE CORRESPONDING PRESSURE  
 COL (K) GIVES THE QUANTITY OF GAS REMAINING IN THE TANK AFTER A TEST AND AVAILABLE FOR COMPRESSION FOR THE NEXT TEST.  
 COL (L) SHOWS THE QUANTITY OF GAS AT 0.2# PRESSURE, WHICH WHEN FORCED INTO A TANK OF THE SIZE SHOWN, WILL GIVE THE DESIRED PRESSURE AT 60° F.  
 COL (M) SHOWS THE QUANTITY OF GAS REMAINING IN EACH TANK AFTER A TEST HAS BEEN MADE AND THE DESIRED QUANTITY REMOVED FOR COMPRESSION INTO THE NEXT TANK.







47












Transfer Pump, Gage, Thermometer, etc.



Regulator for Reducing Pressure.